

**Marysville Borough Sewer & Sanitation Committee**  
**October 6, 2014**  
**5:45 PM**  
**Minutes**

**Chair: Steve Copp     Members: Allen Metzger, Larry Little**

**Operators: Lonnie Sarver, Darrel Binkley**

**1. Punch List Sewer Project**

Work is complete on the project

**2. Time to Think About Next Project**

The committee discussed a time frame to when they would like to see the project started and when the project needed to be complete. Steve said that we should start at least the engineering of the project by 2017 area. That way we could start the grant/loan process. Dave Magee asked the committee about the Ridgeview Drive getting storm water inlets installed. Scott said that this area would not be part of the project since it is already separated.

**3. Pump Station #1**

Scott provided the committee with two invoices for the rebuild of the pumps. Scott stated that Lonnie, Darrel and I have been talking about changing the pumping station to install the proper pumps for the area. Two house hold pumps cannot handle the five homes and two business's. Scott asked the committee if the engineers could look at the pump station to help the borough come up with a better design.

**4. Smoke Testing**

Scott reported that the crew performed a smoke test in the northern part of the borough. Out of all the test there were 82 residence that needed to have a violation letter sent to them to have their down spouts, sump pumps, basement drains and others removed from the sanitary sewer system.

**Next Meeting Monday November 5th, 2014**