

**Marysville Borough Sewer & Sanitation Committee**  
**December 9th, 2010**  
**8:00 AM**  
**MINUTES**

**Chair: Roger Barrick**

**Members: Ann Simonetti, Marcus Hite**

- 1 **Tide Flex Valve** CSO's 2 and 3.  
Scott reported he sent the CD to DEP for their review. Scott believes DEP will have us fix the valves at a cost of \$10,000.00 per valve. We will need at least two.
- 2 **Heater repair** Waiting on quote  
Sewer committee recommended Scott to contact Glenn Orban for a quote for the repair of the heater at the sewer plant.
- 3 **Discuss Blowers** Run time/Energy save  
Scott reported that we need to look at different operating procedures to help energy cost and to help out with longevity of the pumps. Ann suggested calling John Padden from Lemoyne Borough to see what they are doing for cost savings of electric.
- 4 **Air Compressors** Head Works  
Scott reported that the compressors and the control panel are not working properly. We need to have the compressors and control panel working at a proper operational status. Roger suggested once the compressors and control panel are working properly we should look into a service contract.
- 5 **Alarm System**  
Scott reported that the alarm system is working on motion detectors only at the sewer plant. The contacts at the bottom of the overhead doors are broken and will need repaired. The committee recommended Scott wait until spring to have them fixed due to ice issues.

**Next Meeting Thursday, January 6th, 2011 @ 8:00 am**

